

CABINET COMPLIANCE



This document can help you determine the safety and compliance of your storage cabinets, and help keep your operation safe. Start with the Onsite Survey to determine whether a new safety cabinet may be required.

Safety Cabinet Onsite Survey

Use the following questions to determine the safety and compliance of your cabinets. The following graphics give additional information.



QUESTION	RESPONSE	REQUIRED ACTION
Is the flammable safety cabinet in working order and free from rust holes and other defects?	<p>YES → No action required</p> <p>NO → A new flammable safety cabinet may be required</p>	
Have any modifications been made to the original cabinet? <small>(See examples on other page)</small>	<p>YES → A new flammable safety cabinet may be required</p> <p>NO → No action required</p>	
Does the flammable safety cabinet conform to state and/or municipal codes for self-closing doors? <small>(See map on other page)</small>	<p>YES → No action required</p> <p>NO → A compliant cabinet is required</p>	
Does the amount of flammable liquid exceed the following amount? <ul style="list-style-type: none"> 25 Gallons of Class IA liquids in containers (not including a single-day's usage stored within the work area) 120 Gallons of Class IB, IC, II, or III liquids in containers 	<p>YES → Additional flammable safety cabinet(s) are needed.</p> <p>NO → No action required</p>	
Are flammable and corrosive materials stored in the same cabinet?	<p>YES → Store flammable and corrosive liquids in separate flammable safety cabinets</p> <p>NO → No action required</p>	

IMPORTANT: Code requirements for flammable safety can differ from state to state and city to city. Jamco recommends you contact the local authorities in your city for specific requirements.

