Replacement Indications

Signs of wear and deterioration can indicate that it's time to replace your safety cabinet. But did you know that rust and other modifications can mean your cabinet no longer meets code? Modifications include:

- X Welding I-bolts to assist with moving the cabinet
- X Door doesn't close properly
- **x** External attachments to dispense liquids
- X Adding a padlock or drilling any hole in the cabinet
- X Any venting added

State Requirements

Not only do self-closing doors give you peace of mind that your team is protected, most states actually *require* self-closing doors.*





Ready to learn more?

Reach out today, and our team will be glad to assist you. JamcoProducts.com | 800.748.8080 | sales@jamcoproducts.com One Jamco Court, South Beloit IL 61080

Hazard Classifications

FLAMMABLE MATERIALS		
Class IA	Class IB	Class IC
< 100° F Boiling Point	≥ 100° F Boiling Point	73°F (22°C) Flash Point
Diether Ether	Acetone	Xylene
Pentane	Benzene	Naphtha
Ligroin	Cyclohexane	Turpentine
Heptane	Isopropyl	
Petroleum Ether	Alcohol	
	Methyl Ethyl	
	Ketone	
	Toluene	
	Ethanol	

COMBUSTIBLE MATERIALS

Class IIIA	Class IIIB
140°F (60°C) Flash Point	200°F (93°C) Flash Point
Aniline	Animal Oils
Benzaldehyde	Vegetable Oils
Butyl Cellosolve	Ethylene Glycol
Nitrobenzene	Glycerin
Pine Oil	Lubricating
Formaldehyde	Quenching
	Transformer Oils
	Triethanolamine
	Benzyl Alcohol
	Hydraulic Fluids
	140°F (60°C) Flash Point Aniline Benzaldehyde Butyl Cellosolve Nitrobenzene Pine Oil

NOTE: Flammable and Combustible Liquids Code (NFPA 30) is published by the National Fire Protection Association (NFPA). Always check current code requirements for final selection; this is not a complete list. Liquid Classes may be found on product labels and Safety Data Sheet.

*For the most up to date self-closing door requirements, please confirm with your regulatory agencies and consult with your state and local codes. This information is subject to change and is not warranted.

